



Bid Notice Abstract

Request for Quotation (RFQ)

Reference Number 9198277
Procuring Entity PLARIDEL WATER DISTRICT
Title Automatic Transfer Switch (ATS) (ENG PRO 2022-10-042) (PLAWD 2022-11-115)
Area of Delivery Bulacan

Solicitation Number:	PLAWD 2022-11-115	Status	Pending
Trade Agreement:	Implementing Rules and Regulations	Associated Components	2
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	Bid Supplements	0
Classification:	Goods - General Support Services	Document Request List	0
Category:	General Engineering Services	Date Published	08/11/2022
Approved Budget for the Contract:	PHP 175,300.00	Last Updated / Time	07/11/2022 13:51 PM
Delivery Period:	1 Day/s	Closing Date / Time	14/11/2022 01:00 AM
Client Agency:			
Contact Person:	Jim Benzon R. Talavera BAC SECRETARIAT A. C. Reyes St., Poblacion, Plaridel, Bulacan Philippines 3004 63-044-7950102 Ext.103 63-044-7600229 plaridelwaterdistrictbac2017@gmail.com		

Description

PR No. ENG PRO 2022-10-042

Please quote your lowest price on the item/s listed below, subject to the General Conditions, stating the shortest time of delivery and submit your quotation duly signed by your authorized representative.

NOTE:

- 1) The approved budget for the contract is ₱175,300.00
- 2) All entries must be filled up as much as possible.
- 3) Service/Delivery period is within seven (7) calendar days.
- 4) Warranty shall be for a period of three (3) months for supplies and one (1) year for equipment from date of acceptance by the procuring entity.
- 5) Price validity shall be for a period of _____ calendar days.
- 6) PHILGEPS registration certificate shall be attached upon submission of the quotation.
- 7) Bidders shall submit original brochures showing certifications of the product being offered.
- 8) The bidder shall give sample/s of the item/s quoted.
- 9) The bidder shall bear the delivery/return cost of the sample/s.

PURPOSE: Automatic Transfer Switch (ATS)

ITEM NO. QTY/UNIT DESCRIPTION UNIT COST TOTAL COST

1) 1 unit Automatic Transfer Switch for 50 Hp Motor, 440 Volts, 3 Phase, 60 Hz with Variable Frequency Drive Rated 60 Hp

Automatic Transfer Switch Rating: 225 Amperes

Voltage input 440 VAC, 60 hertz, 3 poles, Breaking capacity in 36 kA, Class IP 54 with LCD display/LED indicator controller for manual and auto operation, integrated in Genset controller for dry contact signal input. Installed in a control box, powder coated paintings with power wiring, light indication for manual/auto operations and status for normal/emergency power supply. Control wirings from ATS controller for Signal to start Genset engine must be in applicable standard wire size installed in a rigid steel conduit.

Features and Operations:

TDEN - Time Delay Emergency to Normal Adjustable range 0-999 sec.

TDEN delays the transfer from stand-by power source back to normal power source and to permit stabilization of before the transfer is made. Timing begins when the normal power source becomes available.

TDNE - Time Delay Normal to Emergency: Adjustable range: 0-999 sec

TDNE provides a time delay when transferring the normal power source to stand by power source.

It ensures the standby power source become available

TDEC - Time Delay Engine Cool-down: Adjustable range: 0-999 sec

TDEC permits the generator to continue to run unloaded after the transfer to the normal power has occurred. Timing begins when the transfer to normal has been completed.

Test Mode Simulate a loss of power source

Auto Mode: Automatic Transfer from source to source as dictated by the features supplied and the program values.

SHT Power Delivery TRIP device.

Detection and protection of Power abnormality like under. Over voltage, single phasing, unbalance power, voltage fluctuation, etc.

Include Power Cables & Control Cables, Installation, Testing & Commissioning

> With warranty certificate

Participating bidders "shall" submit samples/brochures of the item/s being

quoted for testing, evaluation and acceptance by the end-user.
****nothing follows****

TOTAL

PLARIDEL WATER DISTRICT
Plaridel, Bulacan
BAC CHECKLIST

- 1) Participating bidders shall submit samples/brochures of the item/s being quoted for evaluation and acceptance of the end-user.
- 2) All payments will be deducted by TAX
Please check the following:
For Goods For Services
(VAT) (VAT)
5% BIR Form 2307 (FVAT) 5% BIR Form 2307 (FVAT)
1% BIR Form 2307 (WHT) 2% BIR Form 2307 (WHT)
(NON-VAT) (NON-VAT)
1% BIR Form 2307 (FVAT) 1% BIR Form 2306 (FVAT)
1% BIR Form 2307 (WHT) 2% BIR Form 2307 (WHT)
- 3) Subject to retention money equivalent to 5% of the contract price.
The retention money period will be released after the warranty period of three months or when the items are consumed whichever comes first
- 4) Brand/Model:
- 5) Delivery Period:
- 6) Warranty Period:
- 7) Price Validity:
- 8) Terms of Payment:
- 10) Mode of payment:
- 11) CHECK PAYABLE TO:
- 12) Company Name:
- 13) Company Address:
- 14) Contact person:
- 15) Contact Number:
- 16) Email Address:
- 17) Tin Number:
- 18) Certificate of Registration (BIR)
- 19) Warranty Certificate
- 20) Availability of Stocks items available as of (Date)

Created by Jim Benzon R. Talavera

Date Created 07/11/2022

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.