



Bid Notice Abstract

Request for Quotation (RFQ)

Reference Number 8477123
Procuring Entity PLARIDEL WATER DISTRICT
Title Plaridel Heights Elevate Water Tank - Water Level Control (ENG PRO 2022-02-007) (PLAWD 2022-02-022)
Area of Delivery Bulacan

Solicitation Number:	PLAWD 2022-02-022	Status	Pending
Trade Agreement:	Implementing Rules and Regulations	Associated Components	2
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	Bid Supplements	0
Classification:	Goods	Document Request List	0
Category:	Water Service Connection Materials/Fittings	Date Published	01/03/2022
Approved Budget for the Contract:	PHP 160,500.00	Last Updated / Time	28/02/2022 16:28 PM
Delivery Period:	7 Day/s	Closing Date / Time	08/03/2022 13:00 PM
Client Agency:			
Contact Person:	Jim Benzon R. Talavera BAC SECRETARIAT A. C. Reyes St., Poblacion, Plaridel, Bulacan Philippines 3004 63-044-7950102 Ext.103 63-044-7600229 plaridelwaterdistrictbac2017@gmail.com		

Description

PR No. ENG PRO 2022-02-007

Please quote your lowest price on the item/s listed below, subject to the General Conditions, stating the shortest time of delivery and submit your quotation duly signed by your authorized representative.

NOTE:

- 1) The approved budget for the contract is ₱160,500.00
- 2) All entries must be filled up as much as possible.
- 3) Service/Delivery period is within seven (7) calendar days.
- 4) Warranty shall be for a period of three (3) months for supplies and one (1) year for equipment from date of acceptance by the procuring entity.
- 5) Price validity shall be for a period of _____ calendar days.
- 6) PHILGEPS registration certificate shall be attached upon submission of the quotation.
- 7) Bidders shall submit original brochures showing certifications of the product being offered.
- 8) The bidder shall give sample/s of the item/s quoted.
- 9) The bidder shall bear the delivery/return cost of the sample/s.

PURPOSE: Plaridel Heights Elevate Water Tank - Water Level Control

ITEM NO. QTY/UNIT DESCRIPTION UNIT COST TOTAL COST

- 1) 1 lot Plaridel Heights Elevate Water Tank - Water Level Control
 >Supply, Installation, Testing and Commissioning of water level control system
 >The system must include the following:
 >100 mm dia.Float valve control ANSI Flange with SS304 float assembly arm and SS304 float ball, ductile arm body brass internal parts, ANSI Flange
 >100 mm dia.Rubber flapper swing check valve ANSI/AWWA C508
 Ductile iron body : ASME B16.42/ ASME B16.50 Class 150
 Color: Epoxy coated blue AWWA C550 300 PSI
 >100 mm dia. WYE Strainer ANSI Flange, ductile iron body
 >The bidder shall submit Site Inspection Certificate
 >The bidder shall submit a Warranty Certificate for the materials installed
 >The bidder shall submit a schematic diagram of the water level control system

NOTE:

Participating bidders "shall" submit samples/brochures of the item/s being quoted for testing, evaluation and acceptance by the end-user.

****nothing follows****

TOTAL

PLARIDEL WATER DISTRICT

Plaridel, Bulacan
BAC CHECKLIST

- 1) Participating bidders shall submit samples/brochures of the item/s being quoted for evaluation and acceptance of the end-user.
- 2) All payments will be deducted by TAX
Please check the following:
For Goods For Services
(VAT) (VAT)
5% BIR Form 2307 (FVAT) 5% BIR Form 2307 (FVAT)
1% BIR Form 2307 (WHT) 2% BIR Form 2307 (WHT)
(NON-VAT) (NON-VAT)
1% BIR Form 2307 (FVAT) 1% BIR Form 2306 (FVAT)
1% BIR Form 2307 (WHT) 2% BIR Form 2307 (WHT)
- 3) Subject to retention money equivalent to 5% of the contract price.
The retention money period will be released after the warranty period of three months or when the items are consumed whichever comes first
- 4) Brand/Model:
- 5) Delivery Period:
- 6) Warranty Period:
- 7) Price Validity:
- 8) Terms of Payment:
- 10) Mode of payment:
- 11) CHECK PAYABLE TO:
- 12) Company Name:
- 13) Company Address:
- 14) Contact person:
- 15) Contact Number:
- 16) Email Address:
- 17) Tin Number:
- 18) Certificate of Registration (BIR)
- 19) Warranty Certificate
- 20) Availability of Stocks items available as of (Date)

Created by Jim Benzon R. Talavera

Date Created 28/02/2022

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.