



# PLARIDEL WATER DISTRICT

A.C. Reyes St., Poblacion, Plaridel, Bulacan 3004  
Tel. Nos. (044) 795-0102 / 795-1613; Fax No. (044) 760-0229  
Email Address: plaridel\_water\_district1987@yahoo.com  
Website: plaridelwaterdistrict.ph



Management System  
ISO 9001:2015  
www.tuv.com  
ID 3108633963



## POSTING CERTIFICATION

This is to certify that the Plaridel Water District has posted its Supplemental Annual Procurement #34 Plan on its agency website and can be accessible through this link: <https://plaridelwaterdistrict.ph/bac2024/>.

This certification is being issued in compliance with GPPB Circular No. 02-2020, this 29 of September, 2025.



**Elias G. Vinta**

Head, Bids and Awards Committee Secretariat

# Supplemental Annual Procurement Plan #34

Code (PAP)	Procurement Project	PMO/End-User	Is this an Early Procurement Activity? (Yes/No)	Mode of Procurement	Schedule for Each Procurement Activity			Source of Funds	Estimated Budget (PHP)		Remarks (Brief description of Project)
					Advertisement Posting or IB/REI	Submission/Opening of Bids	Notice of Award		Contract Signing	Total	
50213030/857	Repair and Maintenance of Transmission/ Distribution Main & Service Line										
	Maintenance of Pipe Lines/ DPWH Road Concreting Project in Tabang	Construction	NO	Shopping	Sept.	N/A	Sept.	Corporate Budget	60,000.00	60,000.00	Shopping 52.1a
	Part of Repair and Maintenance of Transmission/ Distribution Main & Service Line	Construction	NO	NP-53.9 - Small Value Procurement	Sept. - Dec.	N/A	Sept. - Dec.	Corporate Budget	102,369.00	102,369.00	
<b>TOTAL BUDGET:</b>									<b>162,369.00</b>		

Prepared By:

  
 Elias G. Vinta  
 BAC Head Secretariat

Check and Verified By:


  
 Justin Michael B. Berango  
 BAC Chairperson

  
 Charle A. Felicitas  
 BAC Vice Chairperson

  
 Elmer C. Marcelo  
 BAC Member

  
 Alberto A. Mendoza  
 BAC Member

Review and Recommended By:

  
 Dalia Marie H. Tabao  
 Financial Planning Assistant A

  
 Engr. Mario G. Macataangay  
 Interim General Manager

Approved By:

  
 NATHANAEL ANDRES S. BERNABE JR.  
 Head of Procuring Entity









# PLARIDEL WATER DISTRICT

A.C. Reyes St., Poblacion, Plaridel, Bulacan 3004  
 Tel. Nos. (044) 795-0102 / 795-1613; Fax No. (044) 760-0229  
 Email Address: plaridel\_water\_district1987@yahoo.com  
 Website: plaridelwaterdistrict.ph



Management System  
 ISO 9001:2015  
 www.tuv.com  
 ID 9109633953



## INCIDENT REPORT

Date of Incident	September 19, 2025	Reference No.	2025-IR-ENG-MAINTENANCE-09-01
Location/s	Maharlika Highway, Tabang, Plaridel, Bulacan	Inspection/Maintenance Order No.	N/A
<b>Background</b> <p>The Department of Public Works and Highways (DPWH) conducted uncoordinated road maintenance in Tabang, Plaridel, Bulacan, which accidentally damaged the main water line. This caused service disruption and required immediate emergency repair. However, due to the limited stock of 4-inch PVC pipes, the available supply is not sufficient to cover the 735 linear meters affected. Hence, there is an urgent need for emergency procurement of the required pipes to complete the repair and restore normal water service.</p>			
<b>Findings/Observations</b> <ul style="list-style-type: none"> <li>It was noted that the drainage line is located at the middle of the concrete pavement where the road maintenance works are being carried out. This placement contributed to the exposure and damage of the main water line during the activity.</li> </ul>			
<b>Action Taken</b> <ul style="list-style-type: none"> <li>A temporary repair of the damaged mainline was immediately carried out to restore water service while the DPWH's concrete pavement repair project is still ongoing.</li> </ul>			
<b>Recommendation</b> <ul style="list-style-type: none"> <li>It is recommended to proceed with the emergency procurement of 4-inch PVC pipes to sustain the repair of the damaged mainline. This will ensure the continuity of the ongoing works and prevent prolonged water supply disruption along Maharlika Highway near Tabang Elementary School.</li> </ul>			

Prepared by	Noted by
 ENGR. RONALDO C. PICAR	 ENGR. REYNANTE D. FRANCISCO
Senior Engineer A	Division Manager B - Engineering and Technical
Date: 09/19/25	Date: 09/19/25



## ANNEX





<b>FROM THE OFFICE OF THE ENGINEERING DIVISION MANAGER</b>	<b>FOR CONSIDERATION OF THE INTERIM GENERAL MANAGER</b>
SUBJECT <b>Request for Emergency Purchase of 4" Unplasticized Polyvinyl Chloride (PVC) Pipe</b>	DATE <b>September 19, 2025</b>

**BACKGROUND**

The Department of Public Works and Highways (DPWH) conducted uncoordinated road maintenance in Tabang, Plaridel, Bulacan, which accidentally damaged the main water line. This resulted in service disruption and required immediate emergency repair. However, due to the limited stock of 4-inch PVC pipes, the available supply is not sufficient to cover the affected portion of the water distribution system. Hence, there is an urgent need for the emergency procurement of the required pipes to complete the repair and restore normal water service.

**JUSTIFICATIONS**

The emergency procurement of 4-inch uPVC pipes is necessary to address the damage sustained by the PLAWD water distribution line caused by the ongoing maintenance and concreting activities of the Department of Public Works and Highways (DPWH) in Tabang, Plaridel, Bulacan. The available stock of said pipes is currently limited, which poses a serious risk of prolonged water supply disruption should immediate repair not be carried out.

Furthermore, due to the ongoing DPWH project, there remains a high possibility of additional damage to the existing PLAWD water distribution system. To ensure uninterrupted water service to the affected areas and to enable the continuation of necessary repair works, additional procurement of 4-inch uPVC pipes is urgently required.

This emergency procurement is therefore justified to guarantee the immediate and sustained restoration of water supply services to the consumers and to ensure readiness in case of further damage during the project implementation.

**RECOMMENDATION**

It is recommended to proceed with the emergency procurement of 4-inch uPVC pipes to sustain the repair of the damaged mainline. This will ensure the continuity of the ongoing works and prevent prolonged water supply disruption.

PREPARED BY:	REQUESTED BY:	APPROVED BY:
		
RONALDO C. PICAR Senior Engineer A	REYNANTE D. FRANCISCO Division Manager B	MARIO G. MACATANGAY Interim General Manager