



Bid Notice Abstract

Request for Quotation (RFQ)

Reference Number 12934553
Procuring Entity PLARIDEL WATER DISTRICT
Title Supply and Installation Variable Frequency Drive (VFD) Bulihan (ENG PRO 2026-04-014)
 (PLAWD 2026-04-016)
Area of Delivery Bulacan

Solicitation Number:	PLAWD 2026-04-016	Status	In-Preparation
Trade Agreement:	Implementing Rules and Regulations	Associated Components	2
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	Bid Supplements	0
Classification:	Goods	Document Request List	0
Category:	Electronic Parts and Components	Date Published	23/04/2026
Approved Budget for the Contract:	PHP 350,000.00	Last Updated / Time	22/04/2026 14:00 PM
Delivery Period:	7 Day/s	Closing Date / Time	28/04/2026 13:00 PM
Client Agency:			
Contact Person:	Jim Benzon R. Talavera BAC SECRETARIAT A. C. Reyes St., Poblacion, Plaridel, Bulacan Plaridel Bulacan Philippines 3004 63-044-7950102 plaridelwaterdistrictbac2017@gmail.com		

Description

PR No. ENG PRO 2026-04-014

Please quote your lowest price on the item/s listed below, subject to the General Conditions, stating the shortest time of delivery and submit your quotation duly signed by your authorized representative.

NOTE:

- 1) The approved budget for the contract is ₱350,000.00
- 2) All entries must be filled up as much as possible.
- 3) Service/Delivery period is within seven (7) calendar days.
- 4) Warranty shall be for a period of three (3) months for supplies and one (1) year for equipment from date of acceptance by the procuring entity.
- 5) Price validity shall be for a period of _____ calendar days.
- 6) PHILGEPS registration certificate shall be attached upon submission of the quotation.
- 7) Bidders shall submit original brochures showing certifications of the product being offered.
- 8) The bidder shall give sample/s of the item/s quoted.
- 9) The bidder shall bear the delivery/return cost of the sample/s.

PURPOSE: Variable Frequency Drive (VFD) Bulihan

ITEM NO. QTY/UNIT DESCRIPTION UNIT COST TOTAL COST

1) 1 lot Variable Frequency Drive Bulihan
Variable Frequency Drive (VFD) Control Panel
> 40HP, 200-240VAC, 3 phase, 60Hz motor
> With DOL bypass, circuit breaker, contactors, thermal overload relay, enclosure surge protection device, digital multimeter, chlorine controller component, liquid level control, protection against overloading, overheating, and phase imbalance, all enclosed in NEMA
> With running hour meter, fans, selector switches, pilot lights, and nameplates
> Includes 0-10bars, 4-20mA Pressure Transmitter and shielded cable
>Site inspection shall be conducted to accurately verify the size and specifications of the VFD panel box to ensure compatibility and proper installation.

NOTE:

Participating bidders "shall" submit samples/brochures of the item/s being quoted for testing, evaluation and acceptance by the end-user.

****nothing follows****

TOTAL

PLARIDEL WATER DISTRICT

Plaridel, Bulacan

BAC CHECKLIST

1) Participating bidders shall submit samples/brochures of the item/s being quoted for evaluation and acceptance of the end-user.

2) All payments will be deducted by TAX

Please check the following:

For Goods For Services

(VAT) (VAT)

5% BIR Form 2307 (FVAT) 5% BIR Form 2307 (FVAT)

1% BIR Form 2307 (WHT) 2% BIR Form 2307 (WHT)

(NON-VAT) (NON-VAT)

3% BIR Form 2307 (FVAT) 3% BIR Form 2307 (FVAT)

1% BIR Form 2307 (WHT) 2% BIR Form 2307 (WHT)

3) Subject to retention money equivalent to 5% of the contract price.

The retention money period will be released after the warranty period of three months or when the items are consumed whichever comes first

4) Brand/Model:

5) Delivery Period:

6) Warranty Period:

7) Price Validity:

8) Terms of Payment: 15 days 30 days Others

10) Mode of payment:

11) CHECK PAYABLE TO:

12) Company Name:

13) Company Address:

14) Contact person:

15) Contact Number:

16) Email Address:

17) Tin Number:

18) Certificate of Registration (BIR)

19) Warranty Certificate

20) Availability of Stocks items available as of (Date)

Created by Jim Benzon R. Talavera

Date Created 22/04/2026

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.